

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES 1 2
2. AMENDMENT/MODIFICATION NO. #0001	3. EFFECTIVE DATE 02/17/2012	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 3095911	
6. ISSUED BY Contracting Officer (cp) USCG Civil Engineering Unit Cleveland 1240 East Ninth Street, Room 2179 Cleveland, Ohio 44199-2060	CODE	7. ADMINISTERED BY (If other than Item 6) Same as block #6.		CODE

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)		(X)	9A. AMENDMENT OF SOLICITATION NO. HSCG83-12-R-PCR098
		(X)	9B. DATED (SEE ITEM 11) 02/03/2012
			10A. MODIFICATION OF CONTRACT/ORDER NO.
			10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE		

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**


CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
<input type="checkbox"/>	
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return 1 copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

Amendment #0001 is issued to RFP HSCG83-12-R-PCR098 to incorporate the RFI's submitted by the RMACC contractors. The proposal due date remains the same and is March 5, 2012; at 2:30 PM. All offerors must acknowledge receipt of Amendment #0001 with their offer.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
		John R. Pauley Contracting Officer	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		 (Signature of Contracting Officer)	2/17/12

The purpose of this Amendment 0001 is to address questions and answers submitted as RFI's for the above-cited solicitation.

1) Can any additional information be provided about the breaker needed for the existing switchboard? The new work note tells us to provide a 100 amp 3 pole breaker into the existing Cutler/Hammer switchboard. Can they provide a catalog number or breaker frame type for one of the existing breakers in the switchboard?

Response to Question #1: The existing switchboard is ETN/Cutler Hammer POW/R-LINE C.

2) On drawing E-01 Key Note #3 says to provide 3 - #1 & 1 - #8 wire in the new 1 1/2" PVC conduit between the existing switchboard and the new 100 amp panel at the new boat shelter. The new panel at the boat shelter is to be a 3 phase 4 wire panel. I believe this will require 4 - #1 & 1 - #8 wires. Can someone please confirm?

Response to Question #2: Please change 3 #1 to 4 #1.

3) The new panel schedule on E-01 indicates that circuit #6 is for a GFCI receptacle for a fan. I do not see this anywhere on the power & lighting drawing on E-02. Can you please clarify?

Response to Question #3: Please change circuit breaker #6 as spare and not for GFCI receptacle.